



1. PROVIDE SHOP DRAWINGS FOR APPROVAL OF BACKFLOW PREVENTER AND METER ASSEMBLY.
2. PROVIDE CONCRETE PAVING PAD 150 WIDER THAN CABINET DIMENSIONS.
3. DRAIN AND COMPLETELY FLUSH SYSTEM IN THE FALL AND REMOVE METER FOR WINTER STORAGE DURING WARRANTY PERIOD.
4. EQUIPMENT USED FOR WINTERIZATION IS REQUIRED TO BE CERTIFIED AND APPROVED.
5. THE BACKFLOW ASSEMBLY IS REQUIRED TO BE INSTALLED BY A CERTIFIED PLUMBER AND APPROVED BY BUILDING DEPT.
6. ALL FLANGES ARE BRASS.
7. CONCRETE AS PER C-217ITEM 11--CONCRETE) CITY OF BURLINGTON AMENDMENTS TO OPSS



ANCHOR DETAIL

S-143